

CERTIFICATE OF CONFORMITY – WATER BASED FIRE EXTINGUISHING MEDIA

Certificate of conformity reference number: **KB 171/16**

Test specification: Test procedure LM 01-01, test of water based fire extinguishing media, Nov. 29, 2011 except for clause 4.11 – package and marking, see the note below

Test report no.: 20150762

Requested by: Flamark d.o.o., Ante Topića Mimare 40, 10090 Zabreb, CROATIA

Manufacturer: Flamark d.o.o., Ante Topića Mimare 40, 10090 Zabreb, CROATIA

Product name: Flamauto

Type of fire extinguishing medium: Liquid fire extinguishing medium (readymade solution)

Test fire performance: Proof with portable EN 3 fire extinguishers:
21 A, 113 B and 40 F according to EN 3-7 with 6 litres fire extinguishing medium

Freezing point: - 12,7°C

Notes:

1. The fire extinguishing medium is to use undiluted.
2. The information according to clause 4.11 of LM 01-01 for marking shall be stated on the packing or on the storage container.


Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for fire extinguishing media which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

11th July 2016



Grad. Eng. Jürgen Ditttrich
Laboratory Manager

