

The certificate verifies that:

*Brandveilig-Nederland.nl
Neptunusweg 38
8938AA
Leeuwarden
the Netherlands*

Has had tested or assessed for Fire the following product:

Description: *Premium Single Door Access Panel with 2 x Locking Point and a Pivot Hinge.*

Date: *13/05/2015*

Size: *1200 x 900mm*

Result Integrity: *132 minutes no failure*

Orientation: *Wall*

Result Insulation: *99 minutes (EI₂90)*

Duration: *132 minutes*

Report Number: *BMT/FEP/F15113D*

Test Lab: *BMTRADA*


UKAS Testing Procedures: *Yes*

Methodology: *BS EN1634-1 2014 / BS EN1363-1:1999*

*(Please note that where the size of the access panel differs / exceeds the tested size, the access panel is manufactured to the same fire resistant construction.
{ EN Premium Panel Tested Size 1200 x 900 mm})*

Externally audited quality management procedures guarantee full traceability of the manufacturing process for fire rated product specifications.

BS EN ISO 9001:2008 Certificate Number: **GB18691**



This certificate is a short form internal company generated acoustic test evidence of an assessment or test carried out by a UKAS accredited acoustic test laboratory on our behalf. This certificate is designed to provide adequate information for the typical user to assess the suitability of the product presented. If more information is required the full report relating to this certificate is available for inspection at our offices during regular business hours or an abbreviated report can be emailed on request. For reasons of product confidentiality the emailed versions are redacted where necessary to protect the intellectual property of the company.